



TORQUE AND LIMIT SWITCH OPERATION

SWITCH	CLOSE	INTERMEDIATE	OPEN
CLS 1-2			
CLS 1-3			
OLS 1-2			
OLS 1-3			

SYMBOL	DESCRIPTION	RATING
CLS	CLOSE LIMIT SWITCH	250VAC 10A
OLS	OPEN LIMIT SWITCH	250VAC 10A
TP	THERMAL PROTECTOR	250VAC 15A

*EACH ACTUATOR SHOULD BE POWERED THROUGH IT'S OWN INDIVIDUAL SWITCH OR RELAY CONTACTS TO PREVENT CROSS FEED BETWEEN TWO OR MORE ACTUATORS.

DRAW	P.S. KIM	CHECK
DESIGN	S.I. CHOI	APPR.

PART NAME		1PH WIRING DIAGRAM
STANDARD+PCU		
DWG. NO	HQ-1500-A	
ISSU. DEPT. HADR	DATE	2004.05.10

HQ-010
 HQ-008
 APPLICATION HK CONTRAMATIC CO., LTD.

